

Wasserverlust-Tabelle

Druck in Bar	Leck in mm	Wasserverlust				
		Liter/Minute	Liter/Stunde	Kubikmeter/Tag	Kubikmeter/Monat	Kubikmeter/Jahr
12	1	1,72	103	2,5	75	913
	3	15,50	930	22,3	669	8.140
	5	43,00	2.580	61,9	1.857	22.593
	7	84,30	5.058	121,4	3.642	44.311
	9	139,30	8.358	200,6	6.018	73.219
	10	172,00	10.320	247,7	7.431	90.411
10	1	1,60	96	2,3	69	840
	3	14,10	846	20,3	609	7.410
	5	39,30	2.358	56,6	1.698	20.659
	7	76,90	4.614	110,7	3.321	40.405
	9	127,20	7.632	183,2	5.496	66.868
	10	157,00	9.420	226,1	6.783	82.527
8	1	1,40	84	2,0	60	730
	3	12,60	756	18,1	543	6.607
	5	35,10	2.106	50,5	1.515	18.433
	7	68,80	4.128	99,1	2.973	36.172
	9	113,70	6.822	163,7	4.911	59.751
	10	140,40	8.424	202,2	6.066	73.803
6	1	1,20	72	1,7	51	621
	3	10,90	654	15,7	471	5.731
	5	30,40	1.824	43,8	1.314	15.987
	7	59,60	3.576	85,8	2.574	31.317
	9	98,50	5.910	141,8	4.254	51.757
	10	121,60	7.296	175,1	5.253	63.912
4	1	1,00	60	1,4	42	511
	3	8,90	534	12,8	384	4.672
	5	24,80	1.488	35,7	1.071	13.031
	7	48,70	2.922	70,1	2.103	25.587
	9	80,40	4.824	115,8	3.474	42.267
	10	99,30	5.958	143,0	4.290	52.195
2	1	0,70	42	1,0	30	365
	3	6,30	378	9,1	273	3.322
	5	17,60	1.056	25,3	759	9.235
	7	34,40	2.064	49,5	1.485	18.068
	9	56,90	3.414	81,9	2.457	29.894
	10	70,20	4.212	101,1	3.033	36.902

Die Verlustmengen beziehen sich auf den freien Auslauf bei runden Löchern. Der Wasserverlust variiert je nach Ausbildung der Leckstelle.